

# Energy performance certificate (EPC)

Millstream Close  
LONDON  
N13 6EF

Energy rating

D

Valid until: 13 April 2034

Certificate number: 2124-1119-8016-9112-1159

Property type

Top-floor flat

Total floor area

30 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property's energy rating is D. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+   | A             |         |           |
| 81-91 | B             |         |           |
| 69-80 | C             |         | 80 C      |
| 55-68 | D             | 62 D    |           |
| 39-54 | E             |         |           |
| 21-38 | F             |         |           |
| 1-20  | G             |         |           |

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                 | Rating    |
|----------------------|---------------------------------------------|-----------|
| Wall                 | Timber frame, as built, insulated (assumed) | Good      |
| Roof                 | Flat, insulated (assumed)                   | Average   |
| Window               | Fully double glazed                         | Average   |
| Main heating         | Room heaters, electric                      | Very poor |
| Main heating control | Programmer and appliance thermostats        | Good      |
| Hot water            | Electric immersion, standard tariff         | Very poor |
| Lighting             | Low energy lighting in all fixed outlets    | Very good |
| Floor                | (another dwelling below)                    | N/A       |
| Secondary heating    | None                                        | N/A       |

### Primary energy use

The primary energy use for this property per year is 343 kilowatt hours per square metre (kWh/m<sup>2</sup>).

---

## How this affects your energy bills

An average household would need to spend **£1,050 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £505 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

### Heating this property

Estimated energy needed in this property is:

- 1,433 kWh per year for heating
  - 1,793 kWh per year for hot water
-

## Impact on the environment

This property's environmental impact rating is D. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

### Carbon emissions

An average household produces 6 tonnes of CO2

This property produces 1.8 tonnes of CO2

This property's potential production 1.7 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Changes you could make

| Step                                                 | Typical installation cost | Typical yearly saving |
|------------------------------------------------------|---------------------------|-----------------------|
| 1. Add additional 80 mm jacket to hot water cylinder | £15 - £30                 | £64                   |
| 2. High heat retention storage heaters               | £800 - £1,200             | £443                  |

### Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

### More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](https://www.gov.uk/improve-energy-efficiency)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                 |                                                                                |
|-----------------|--------------------------------------------------------------------------------|
| Assessor's name | Christopher Dela Cruz                                                          |
| Telephone       | 07883027430                                                                    |
| Email           | <a href="mailto:chris@getpropertyready.co.uk">chris@getpropertyready.co.uk</a> |

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                      |                                                      |
|----------------------|------------------------------------------------------|
| Accreditation scheme | ECMK                                                 |
| Assessor's ID        | ECMK304553                                           |
| Telephone            | 0333 123 1418                                        |
| Email                | <a href="mailto:info@ecmk.co.uk">info@ecmk.co.uk</a> |

### About this assessment

|                        |                       |
|------------------------|-----------------------|
| Assessor's declaration | No related party      |
| Date of assessment     | 13 April 2024         |
| Date of certificate    | 14 April 2024         |
| Type of assessment     | <a href="#">RdSAP</a> |

---